WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69514
Permit No. 62310
Basin 162

NOTICE OF INTENT NO. 16305

1. OWNER Forum Group Limited
MAILING ADDRESS SW SE
ADDRESS AT WELL LOCATION Hwy. 372 + Happy Ln.

2. LOCATION NW ¼ SW ¼ Sec. 19 T. 20S N/S R. 53 E. Nye County
PERMIT NO. 62310 (Issued by Water Resources) | 36-351-16 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	30	30
Silty Clay, 10 to 20% Caliche.		30	170	140
Sandy Clay 20% Caliche		170	260	90
Silty Clay.		260	370	110
Sandy clay 20% Caliche		370	440	70
Sandy clay 40% Caliche		440	560	120
Silty Clay		560	580	20
Sandy Clay. 40% Caliche		580	740	160
Sandy Clay 20% Caliche		740	810	70
Sandy Clay, Small Gravel.		810	830	20
		830	1020	190

Date started 7-10, 1997
Date completed 11-15, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1020 Feet Depth Cased 1020 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17½ Inches		0 Feet	120 Feet
12¼ Inches		120 Feet	1020 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	22.36	¼"	+1	1020

Perforations:
Type perforation Boscoe Moss Full Flow Louvered
Size perforation .050 Slot.
From 280 feet to 300 feet
From 340 feet to 440 feet
From 460 feet to 560 feet
From 600 feet to 880 feet
From 960 feet to 980 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 Ft.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 1020 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426.
Signed [signature] By driller performing actual drilling on site or contractor
Date 12-8-97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627