WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69520
Permit No.
Basin 212

NOTICE OF INTENT NO. 17365

1. OWNER CALNEV PIPE LINE CO
MAILING ADDRESS c/o GATX TSTC, 2020 E. SEPULVEDA BLVD., CARSON, CA 90810
ADDRESS AT WELL LOCATION NEC of Valley View and Hacienda.

2. LOCATION NW ¼ SW ¼ Sec. 29 T 21 N(S) R 61 E Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 162-29-301-001 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE RW-30
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.5	.5
Sandy silt		0.5	8.5	8.0
Caliche		8.5	10	1.5
Sandy silt		10	11	1
Silty clay w/gravel		11	14	3
Caliche		14	15	1
Clayey silt		15	17	2
Clay w/silt		17	19	2
Silty clay		19	22.5	3.5
Clayey silt		22.5	26	3.5
Silty sand w/gravel		26	34	8
Caliche		34	37	3
Clay w/silt		37	46	9
Caliche		46	49	3
Clay w/sand		49	~~68~~ 58	09
Clay w/silt + sand		~~68~~ 58	68	10
Sandy clay		68	75	8

Date started October 27, 1997
Date completed October 27, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
←	NA	→

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	75 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5"	2.0	0.25	0	75

Perforations:
Type perforation Factory slotted
Size perforation 0.020"
From 45 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-35'
Placement Method: ☐ Pumped ☒ Poured
Bentonite placed from 35-40'
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 40 feet to 75 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tom High
Contractor
Address Converse Consultants, 731 Pilot Rd., Suite H, Las Vegas, NV 89119
Contractor
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11869
Signed
By driller performing actual drilling on site or contractor
Date 12/15/97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627