I

WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69522
Permit No.
Basin 212

NOTICE OF INTENT NO. 16593

1. OWNER Jeff Gibson
MAILING ADDRESS Ampac Development Co
3770 Howard Hughes Pkwy #300 LV NV 89107

ADDRESS AT WELL LOCATION
Right-of-way
Henderson

2. LOCATION NE ¼ NW ¼ Sec. 15 T. 21 N/S R. 62 E. County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	4"	
well graded sand w/ gravel		4"	2'	
gravel sand cobbles		2'	11'	
sand w/clay & gravel		11'	20'	
gravel		20'	40'	
▽	41			
gravel			55.5	

Date started NOV 18, 1997
Date completed NOV 19, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2"	4	10'	1 hr

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		sch 40	0	30

Perforations:
Type perforation machine slotted
Size perforation 020
From 30 feet to 55 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 27 feet to 55 feet

9. WATER LEVEL
Static water level 41 feet below land surface
Artesian flow 5 G.P.M. P.S.I.
Water temperature 70 °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Geotechnical Envir. Services
Contractor
Address 7560 W. Sahara LV NV 89117
Contractor

Nevada contractor's license number issued by the State Contractor's Board Engineer
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044
Signed [signature]
By driller performing actual drilling on site or contractor
Date 12/19/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627