WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69557
Permit No. 84
Basin

NOTICE OF INTENT NO. 3912

1. OWNER RANY & ROBIN SIMPSON
MAILING ADDRESS P.O. Box 6361
Reno, Nevada 89513

ADDRESS AT WELL LOCATION 6005 Prarie Dog
Reno, Nevada 89510

2. LOCATION NW ¼ NE ~~NW~~ ¼ Sec. 14 T. 22N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-140-15 (Parcel No.) Palomino Valley Unit 3 14.2.0.3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	15	14
White sandy clay		15	18	3
Brown sandy clay		18	63	45
Blue sandy clay		63	91	28
Gray sandy clay		91	124	33
Soft zone (app 2 GPM)	X	124	125	1
Gray sandy clay		125	163	38
Soft zone	X	163	164	1
Gray clay		164	171	7
Soft zone	X	171	194	23
Gray clay streaks		194	196	2
Soft zone, fine sands		196	199	3
Gray clay		199	200	1

Date started 6-3-97, 19
Date completed 6-5-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 155 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 foot
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Mary C. Hoeman (By driller performing actual drilling on site or contractor)
Date June 9, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627