

OFFICE USE ONLY
 Log No. 69564
 Permit No. 84
 Basin 84

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35386

1. OWNER Dale & Jessica Morton ADDRESS AT WELL LOCATION 6100 Lost Springs Rd.
 MAILING ADDRESS 6100 Lost Springs Rd. Reno, NV 89510
 2. LOCATION NE 1/4 NE 1/4 Sec. 3 T. 22 N/S R. 20 East Washoe County
 PERMIT NO. 076-120-10 Parcel No. 076-120-10 Subdivision Name Washoe County
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Multi color course sand		387	410	23
Light brown clay		410	435	25
Multi color course sand	X	435	460	25
Brown clay with multi color course sand		460	525	65
Multi colored gravel		525	540	15
Multi color course sand		540	565	25
Multi colored gravel	X	565	575	10
Brown clay with multi color course sand		575	610	35
Multi colored gravel		610	625	15
athered gravel with multi color course sand		625	705	80
Multi color gravel with brown clay		705	710	5
Course sand with multi colored gravel		710	825	115
<i>Deepening of log at 575'</i>				
T.D. 825'				

8. WELL CONSTRUCTION
 Depth Drilled 825 Feet Depth Cased 775 Feet
 HOLE DIAMETER (BIT SIZE)
 From 5 5/8 Inches To 800 Feet
 From 386 Feet To 800 Feet
 From 386 Feet To 800 Feet
 From 386 Feet To 800 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	6.56	.188	247	775

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3
 From 755 feet to 775 feet
 From 555 feet to 575 feet
 From 435 feet to 455 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal In Place
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From feet to feet

9. WATER LEVEL
 Static water level 205 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address P.O. Box 60130 Contractor
Reno, NV 89506

Nevada contractor's license number 35387-A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2066
 Division of Water Resources, the on-site driller
 Signed James Welch
 By driller performing actual drilling on site or contractor
 Date September 29, 1997

Date started August 26, 1997
 Date completed September 6, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>12</u>	<u> </u>	<u>2 Hrs.</u>