

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **69574**  
 Permit No. **162**  
 Basin **162**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **16354**

1. OWNER **RODRIQUEZ, JOSE** ADDRESS AT WELL LOCATION **1711 CORDOVA**  
 MAILING ADDRESS **1711 CORDOVA PAHRUMP, NV 89048**

2. LOCATION **SE** 1/4 **NW** 1/4 Sec. **20** T **19S** N/S **R 53E** E **NYE** County  
 PERMIT NO. **29-388-01** **CRYSTALAIRES ESTATES**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & CLAY		0	63	63
CLAY & GRAVEL		63	74	11
CLAY		74	86	12
GRAVEL	WB	86	98	12
CLAY		98	113	15
GRAVEL	WB	113	120	7
CLAY		120	128	8
GRAVEL	WB	128	140	12

8. WELL CONSTRUCTION  
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
**12.25** Inches **0** Feet **140** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>8.625</b>	<b>16.94</b>	<b>.188</b>	<b>0</b>	<b>140</b>

Perforations:  
 Type perforation **FACTORY SAW CUT**  
 Size perforation **1/8 X 3**

From **100** feet to **120** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50** \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **140** feet



Date started **8/11/97** \_\_\_\_\_, 19\_\_\_\_  
 Date completed **8/15/97** \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level **49** feet below land surfac  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Great Basin Drilling Co.** Contractor  
 Address **PO BOX 4220** Contractor  
**PAHRUMP, NV 89041**  
 Nevada contractor's license number issued by the State Contractor's Board **30880**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**  
 Signed *Thomas D...*  
 By driller performing actual drilling on-site or contractor  
 Date **12/17/97**

