


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. **69576**  
 Permit No. \_\_\_\_\_  
 Basin **162**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **16164**

1. OWNER **JERRY BAUMAN**  
 MAILING ADDRESS **2631 W. WILSON PAHRUMP, NV 89048**  
 ADDRESS AT WELL LOCATION **2631 W. WILSON**

2. LOCATION **NE 1/4 SW 1/4 Sec. 18 T 20S N/S R 53E E NYE** County  
**CHARLESTON PARK RANCHOS**  
 PERMIT NO. **36-201-05** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & CALICHE		0	58	58
CALICHE	WB	58	70	12
CLAY		70	88	18
CALICHE	WB	88	96	8
CLAY		96	114	18
CALICHE	WB	114	125	11
CLAY		125	135	10
CALICHE	WB	135	140	5

8. WELL CONSTRUCTION  
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)  
 From **12.25** Inches To **0** Feet **140** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>8.625</b>	<b>16.94</b>	<b>.188</b>	<b>0</b>	<b>140</b>

Perforations:  
 Type perforation **FACTORY SAW CUT**  
 Size perforation **1/8" X 3"**  
 From **100** feet to **120** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50** \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **140** feet



Date started **8/18/97**, 19\_\_\_\_  
 Date completed **8/22/97**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Bailer	Pump	
	Draw Down (Feet Below Static)		

9. WATER LEVEL  
 Static water level **58** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Great Basin Drilling Co.** Contractor  
 Address **PO BOX 4220** Contractor  
**PAHRUMP, NV 89041**

Nevada contractor's license number issued by the State Contractor's Board **30880**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed *Steve S. [Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **8-22-97**

