

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33910

Consultant: _____
 1. OWNER SHAW ENGINEERING
 MAILING ADDRESS 430 Stoke Ave., Suite 207
Reno, Nevada 89503
 Owner: _____
 ADDRESS AT WELL LOCATION SEVEN-UP BOTTLING CO
1000 Terminal Way OF RENO
Reno, Nevada 89502
 2. LOCATION NE 1/4 SW 1/4 Sec 18 T. 19N N/S R. 20 E Washoe County
 PERMIT NO. 19341 013-322-19 Parcel No. Reno Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Commercial Irrigation Test
 Municipal Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Total Depth				62.9 ft.
Static Water Level				15.9 ft.
WELL ABANDONMENT:				
6-9-97				
1. Attempt to pull casing, 8 inch OD				
2. Perforate casing from 56' back to 18', 4 holes around on 1' intervall, slot size 1/2 x 2 3/4"				
3. Install tremie pipe to 61 ft. Mix and pump 21 sacks from bottom. Pull 21 ft of tremie pipe, mix and pump 18 sacks cement from 40 ft. Cement filling casing to overflow. Cover hole.				
6-10-97				
1. Measure cement drop. Cement @ 12.8 ft / Water @ 11.8 ft.				
2. Dig down around casing, cut below grade, Cement to surface and back fill. Clean up site. Dispose of concrete.				
Equipment: T660 Schramm Drill, perforator High pressure mixer & pump, 61 ft. tremie pipe				
Materials: 42 sacks Portland Cement Type II				
Date started <u>6-9-97</u> , 19.....				
Date completed <u>6-10-97</u> , 19.....				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From	To
_____ Inches	_____ Feet
_____ Inches	_____ Feet
_____ Inches	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____

Size perforation _____

From	feet to	feet

Surface Seal: Yes No Seal Type: _____

Depth of Seal _____ Neat Cement

Placement Method: Pumped Cement Grout

Poured Concrete Grout

Gravel Packed: Yes No

From _____ feet to _____ feet

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL

Static water level _____ feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor

Address P.O. BOX 12370 Contractor

RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed Wayne Drilling, Inc. By driller performing actual drilling on site or contractor

Date June 13, 1997