

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37116

1. OWNER MIKE & COLLEEN DEWITT ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 14095 Red Rock Road
Reno, Nevada 89506
 2. LOCATION SEW 1/4 NEW 1/4 Sec. 2019 T 22N N/S R. 19 E Washoe County
 PERMIT NO. 079-361-02 Red Rock Estates # 125
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	11	11
Cemented gravels & sand		11	20	9
Brown sandy clay		20	109	89
Soft zone (NO WATER)		109	111	2
Green sandy clay		111	127	16
Brown sandy clay		127	181	54
Green sandy clay		181	190	9
Soft zone (NO WATER)		190	193	3
Gray sandy clay		193	221	28
Soft zone (app 6 GPM)	X	221	229	8
Gray sandy clay		229	280	51
Soft zone	X	280	284	4
Gray sandy clay		284	300	16

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
8 5/8 Inches 50 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 220 feet to 240 feet
 From 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 300 feet

Date started 10-27-97, 19____
 Date completed 10-28-97, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
17		

9. WATER LEVEL
 Static water level 197 feet below land surface
 Artesian flow _____ G.P.M. 17 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC.
 Address P.O. BOX 12370
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date October 29, 1997