

Log No. 69604  
 Permit No. 2A  
 Basin. I

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 3539

1. OWNER Byron Wholey ADDRESS AT WELL LOCATION 10405 Silver Spur Drive  
 MAILING ADDRESS 10405 Silver Spur Drive 10405 Silver Spur Drive  
Reno, NV 89506 Reno, NV 89506

2. LOCATION SE 1/4 Sec 21 T. 21 N. R. 18 East Washoe County  
 PERMIT NO. NE 087-363-08 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown D.G.		0	10	10
Brown Clay		10	20	10
Light Brown Clay w/ White & Black Course Sand		20	60	40
Gray Sticky Clay		60	100	40
Gray Clay w/ Multi Colored Course Sand		100	150	50
Gray Sticky Clay		150	175	25
Multi Colored Course Sand	X	175	200	25
Multi Colored Fine Sand	X	200	220	20

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1 1/2	220

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32 X 3  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 220 feet to 50 feet

9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started October 31, 1997  
 Date completed November 3, 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>2 Hours</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service, Inc.  
P.O. Box 60130 Contractor  
 Address \_\_\_\_\_ Contractor  
Reno, NV 89506

Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066

Signed Tony White  
 By driller performing actual drilling on site or contractor  
 Date November 3, 1997

RECEIVED  
 T.D. 220  
 97 NOV 14 AM 1:06  
 STATE ENGINEERS OFFICE