

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 69607  
 Permit No. 92A  
 Basin                     

NOTICE OF INTENT NO. 33913

1. OWNER MARK & CATHY MEICH ADDRESS AT WELL LOCATION 1225 Argosy Road  
 MAILING ADDRESS 7360 Remington Rd. Red Rock Estates  
Reno, Nevada 89506  
 2. LOCATION NE 1/4 NW 1/4 Sec 19 T.22N N/S R. 19E E Washoe County                       
 PERMIT NO. 079-362-11 Parcel No.                      Subdivision Name Red Rock Estates #160  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well     Replace     Recondition  
 Deepen     Abandon     Other.....  
 4. PROPOSED USE  
 Domestic     Irrigation     Test  
 Municipal/Industrial     Monitor     Stock  
 5. WELL TYPE  
 Cable     Rotary     RVC  
 Air     Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
Brown Sandy Clay		1	38	37
Decomposed Granite cemented		38	51	13
Brown Sandy Clay		51	92	41
Soft Zone, Fine Brown sand		92	95	3
Brown Sandy Clay		95	215	120
Gray Sandy Clay		215	279	64
Soft Zone (no water)		279	280	1
Gray Sandy Clay		280	307	27
Soft Zone (app 1 GPM)	X	307	309	2
Gray Sandy Clay		309	360	51
Soft Zone (app 4 GPM)	X	360	362	2
Gray Sandy Clay		362	399	37
SOFT Zone	X	399	400	1
Gray Sandy Clay		400	404	4
Green Volcanic Rock		404	434	30
Soft Zone	X	434	435	1
Green Volcanic Rock		435	440	5
Gray Volcanic Rock		440	464	24
Soft Zone	X	464	465	1
Gray Volcanic Rock		465	475	10

8. WELL CONSTRUCTION  
 Depth Drilled 475 Feet    Depth Cased 475 Feet  
 HOLE DIAMETER (BIT SIZE)  

	From	To
<u>10</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>8 5/8</u> Inches	<u>50</u> Feet	<u>475</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>475</u>

Perforations:  
 Type perforation Factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 315-335 feet to 355-375 feet  
 From 395-415 feet to 435-455 feet  
 From                      feet to                      feet  
 From                      feet to                      feet  
 From                      feet to                      feet

Surface Seal:  Yes     No    Seal Type:  
 Depth of Seal 50     Neat Cement  
 Placement Method:  Pumped     Cement Grout  
 Poured     Concrete Grout  
 Gravel Packed:  Yes     No  
 From 50 feet to 475 feet

9. WATER LEVEL  
 Static water level 288 feet below land surface  
 Artesian flow                      G.P.M. 17 P.S.I.  
 Water temperature cold °F    Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, Nevada 89510  
 Nevada contractor's license number issued by the State Contractor's Board 0022549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed                      June 11, 1997  
 By driller performing actual drilling on site or contractor  
 Date                     

Date started 6-6-97, 19  
 Date completed 6-9-97, 19

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>17</u>			