WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 5765
Permit No.
Basin 100

NOTICE OF INTENT NO. 37087

1. OWNER Dan & Marla James
MAILING ADDRESS 190 South Avenue
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 190 South Avenue
Reno, Nevada 89506

2. LOCATION SW ¼ SW ¼ Sec. 29 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) | 081-182-10 (Parcel No.) | Cold Springs (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	9	8
Brown sandy clay with gravels		9	36	27
Brown sandy clay		36	61	25
Light brown sandy clay		61	112	51
Coarse sands	X	112	116	4
Brown clay		116	132	16
Coarse sands with streaks of clay	X	132	160	28
Gray clay		160	165	5

Date started 9-12-97, 19
Date completed 9-12-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	165 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	165

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 100 feet to 120 feet
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date September 17, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627