

Log No. 6708  
 Permit No. 105  
 Basin NA

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31626

1. OWNER BROOKS PARK ADDRESS AT WELL LOCATION SAME  
 MAILING ADDRESS 860 Hwy 395  
GARDNERVILLE, NV 89410  
 2. LOCATION SW 1/4 SE 1/4 Sec. 14 T. 12 N/S R 20 E Douglas County  
 PERMIT NO. NA 29 020 03 Parcel No. NA Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HAY FIELD LOAM		0	1	1
SILT, SAND + COBBLES		1	20	19
COBBLES + BLOBS	X	20	80	60
SOME S + GRVL				
V. MINOR BROWN CLAY				
MORE BLOBS	X	80	100	20
SAND, GRVL, COBLS + BLOBS - TYPICAL	X	100	190	90
RIVER / FLUVIAL SEDIMENTS				

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 190 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>190</u>

Perforations:  
 Type perforation SAWCUT  
 Size perforation 3 x 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 160 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100 FT  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 190 feet

9. WATER LEVEL  
 Static water level 25 feet below land surface  
 Artesian flow No G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality \_\_\_\_\_

Date started 7/29 1997  
 Date completed 8/5 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>		<u>34hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, INC Contractor  
 Address 75 LEWERS CTR RD Contractor  
CARSON CITY, NV 89704  
 Nevada contractor's license number 13697A  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1790  
 Division of Water Resources, the on-site driller.  
 Signed Joe Leisak  
 By driller performing actual drilling on site or contractor  
 Date 11/18/97

RECEIVED  
 97 NOV 21 AM 11:01  
 STATE ENGINEER'S OFFICE