WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69620
Permit No. 105
Basin

NOTICE OF INTENT NO. 37223

1. OWNER Williams Ridge Technology Park
MAILING ADDRESS 119B Sawmill Rd
Gardnerville Nv 89410

ADDRESS AT WELL LOCATION Between the upper + Lower Allerman canals N. of Pinenut Rd. Gardnerville, N

2. LOCATION NE ¼ SW ¼ Sec. 2 T. 12 N/S R. 20 E. Douglas County

PERMIT NO. AOITA (Issued by Water Resources) 2348024 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
small cobbles + gravel		0	5	
silty		5	15	
silty clayey		15	30	
silty clayey w/some gravel		30	38	
sandy gravel		38'	58	

Plugged by Well
log 126738
Replaced by Well
log 126739

RECEIVED
97 NOV 25 PM 1:06
STATE ENGINEERS OFFICE

Date started 11-11, 1997
Date completed , 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 58 Feet Depth Cased 57.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	58 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.37		SCH 40	+6"	40
"		"	52.5	57.5

Perforations:
Type perforation screen
Size perforation .020
From 40 feet to 52.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal Cemt 0'-10' Bent. 10-37'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout ☑ Bent grout
Gravel Packed: ☑ Yes ☐ No
From 37 feet to 58.0 feet

9. WATER LEVEL
Static water level 43 + feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling Inc (Contractor)
Address 75 Lewers creek RD (Contractor)
Carson city Nv 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John G. Lewis
By driller performing actual drilling on site or contractor
Date 11-18-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627