

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31624

1. OWNER W. Duckworth ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2792 CLAPHAM  
GARDNERVILLE, NV 89410  
 2. LOCATION NE 1/4 NE 1/4 Sec 33 T 14 S R 20 E Douglas County  
 PERMIT NO. 21 100 06 Parcel No. NA Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CORRAL LOAM		0	10"	10"
GREY HARD SAND		10"	20	19+
COMPACT SAND W MINOR BRWN CLAY		20	40	20
CLAYEY SAND, GRY-BRWN		40	60	20
AS ABOVE W SMALL COBBLES LITTLE GRVL	X	60	80	20
SANDY BRWN CLAY MOIST		80	100	20
SAND W SMALL GRVLS X	X	100	120	20
GRVL W AB SAND	X	120	140	20
BRWN SANDY CLAY		140	145	5

8. WELL CONSTRUCTION  
 Depth Drilled 145 Feet Depth Cased 145 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 145 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>15</u>	<u>.188</u>	<u>+2</u>	<u>145</u>

Perforations:  
 Type perforation SAWCUT  
 Size perforation 3x 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 105 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 145 feet

9. WATER LEVEL  
 Static water level 38 feet below land surface  
 Artesian flow No G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started 8/7 1997  
 Date completed 8/8 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>100+</u>		<u>3</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, Inc Contractor  
 Address 75 LEWERS CRK Rd Contractor  
CARSON CITY, NV 89704  
 Nevada contractor's license number 13695A  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1790  
 Division of Water Resources, the on-site driller.  
 Signed Joe Reisch  
 By driller performing actual drilling on site or contractor  
 Date 11/18/97