

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32645

1. OWNER Delamar: Theresa Watson ADDRESS AT WELL LOCATION: 2493 East Valley Rd Gardnerville NV 89423  
MAILING ADDRESS: 2493 East Valley Rd Gardnerville NV 89423

2. LOCATION NE  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec 3 T. 13 S R. 20 E. Douglas County  
PERMIT NO. 23-070-01 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mill

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Hard Pan and Gravels</u>		<u>3</u>	<u>67</u>	<u>64</u>
<u>Brown Clay</u>		<u>67</u>	<u>110</u>	<u>43</u>
<u>Fine Sands</u>		<u>110</u>	<u>140</u>	<u>30</u>
<u>Gummy Brown Clay</u>		<u>140</u>	<u>187</u>	<u>47</u>
<u>Small Obsidian Gravel Fractures</u>	<u>xx</u>	<u>187</u>	<u>220</u>	<u>33</u>

8. WELL CONSTRUCTION  
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)  
From 10/4 Inches To 0 Feet 220 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13.23</u>	<u>.188</u>	<u>0</u>	<u>220</u>

Perforations:  
Type perforation Mill Slot  
Size perforation 3 x 3/32  
From 200 feet to 220 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 55  Cement Grout  
Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
From 55 feet to 220 feet

9. WATER LEVEL  
Static water level 75 feet below land surface  
Artesian flow G.P.M. 20 P.S.I.  
Water temperature Cold °F Quality Good

Date started 10-2 1997  
Date completed 10-6 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>85</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Capital City Well Drilling Contractor  
Address 20 Kit Kat Dr. Carson City NV 89706 Contractor  
Nevada contractor's license number 41775 issued by the State Contractor's Board.  
Nevada driller's license number issued by the Division of Water Resources 1905 on-site driller  
Signed N. Michael L. Hark  
By driller performing actual drilling on site or contractor  
Date 10-7-97