

OFFICE USE ONLY
 Log No. 69625
 Permit No. 105
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32643

1. OWNER Ryan Petty ADDRESS AT WELL LOCATION 1132 East Valley Rd Gardnerville Nv. 89423
 MAILING ADDRESS 1132 East Valley Rd Gardnerville Nv. 89423
 2. LOCATION NE 1/4 NE 1/4 Sec 12 T 12 S R 20 E Douglas County
 PERMIT NO. 23-211-12 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard Pan		0	4	4
Course Gravels and Sands		4	87	84
Brown Clay		87	125	38
Course Fine Sands (Soft)		125	140	15
Brown Gummy Clay		140	165	25
Broken Volcanic Fractures (Hard)	XXX	165	190	25

8. WELL CONSTRUCTION
 Depth Drilled 190 Feet Depth Cased 190 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 1/4 Inches 0 Feet 190 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>190</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 170 feet to 190 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 190 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature Cold °F Quality Good

Date started 9/25 1997
 Date completed 9/30 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>25</u>	<u>70</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling
 Address 20 Kit Kat Dr. Carson City Nv. 89423
 Nevada contractor's license number issued by the State Contractor's Board 1905 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Haek
 By driller performing actual drilling on site or contractor
 Date 9/30/97