WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69036
Permit No.
Basin 105

NOTICE OF INTENT NO. 33679

1. OWNER Jack Smith
MAILING ADDRESS 3530 Cherokee
C.C. NV 89705

ADDRESS AT WELL LOCATION 3530 Cherokee

2. LOCATION NE ¼ NE ¼ Sec. 12 T. 14 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) 13-080-20 (Parcel No.) Jacks Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☒ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
* see notes below				
Abandoned existing well 6" 151'		0	151	
New Well				
top soil & overburden		0	10	
DG Sand & Light gravel		10	45	
Sand		45	75	
Sand & Light gravels		75	145	
Clay & Sand	X	145	190	
Clay Sand & gravel		190	225	
Sand & sandstone	XX	225	350	

* Plugging of well log # 14668, Domestic well T.D. 155', 6 5/8 casing from 0 - T.D., .156 thickness perfs at 120-150', mill slot 3"x3/32" seal from 0-45'

Date started 8-8, 1997
Date completed 8-15, 1997

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	30+		3½ hrs.

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	350 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	11.5 lbs	.186	0	350

Perforations:
Type perforation Rotary
Size perforation 3"x5/32"
From 330 feet to 310 feet
From 230 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 350 feet to 50 feet

9. WATER LEVEL
Static water level 86 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kawchack Drilling Inc (Contractor)
Address PO Box 1359 (Contractor)
Minden NV 89423
Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-15-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627