

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 83678

1. OWNER Dennis Murphy ADDRESS AT WELL LOCATION 422 Claire cat
 MAILING ADDRESS 422 Claire cat
Goodspeedville NV 89410

2. LOCATION NE 1/4 NE 1/4 Sec. 22 T. 12 N/S R. 19 E Douglas County
 PERMIT NO. 19-280-40 Parcel No. Foot Hill Rd Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil & Sand & rock		0	5	
small boulders large rock		5	20	
Sand & large rock		20	65	
Sand		65	85	
Sand & large rocks	X	85	110	
Sand		110	120	
Sand & ROCKS	Y	120	175	
Sand & small rock		175	220	

12 SEP 2 AM 8:39
 STATE ENGINEERING SERVICE

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 7/16 Inches To 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>11.5/16</u>	<u>.188</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation Endcap
 Size perforation 5" x 3/16"

From _____ feet to _____ feet
 From 220 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 220 feet to 50 feet

9. WATER LEVEL
 Static water level 76 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 7-18 1997
 Date completed 7-22 1997

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>45</u>		<u>3 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kowchek Drilling Inc. Contractor
 Address PO Box 1359 Contractor
Minden NV 89423

Nevada contractor's license number issued by the State Contractor's Board #021268
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #4495

Signed Michael Allen
 By driller performing actual drilling on site or contractor

Date 7-22-97