

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **69652**
 Permit No. _____
 Basin **16a**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **15575**

OWNER **MIKE GRIFFIN** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **981 W. JARVIS PAHRUMP, NV 89048** **981 W. JARVIS PAHRUMP, NV**

2. LOCATION **S/W** 1/4 **N/W** 1/4 Sec. **28** T **19S** N/S R **53E** E **NYE** County
 PERMIT NO. **29-901-01** **BELL VISTA** Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY LOAM		0	8	8
BROWN CLAY		8	20	12
LIGHT BROWN CLAY		20	36	16
BROWN CLAY		36	48	12
BROWN CALICHIA		48	59	11
BROWN CLAY		59	64	5
DARK BROWN CLAY	X	64	85	21
BROWN CLAY	X	85	110	25
CLAY	X	110	130	20
GREY CLAY	X	130	140	10

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140** Feet
 HOLE DIAMETER (BIT SIZE)
 From **12 7/8** Inches To **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	104	136

Perforations:
 Type perforation **SAW CUT**
 Size perforation **0.188**
 From **110** feet to **130** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal **50** Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **140** feet



9. WATER LEVEL
 Static water level **65** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **COLD** °F Quality **GOOD**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road Suite 2** Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**
 Signed *Larry Strickland*
 By driller performing actual drilling on site or contractor
 Date **8.21.97**

Date started **8/20/97** .19
 Date completed **8/20/97** .19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	50	N/A	.50



KC