

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **69653**
 Permit No. **162**
 Basin **162**
 NOTICE OF INTENT NO. **15553**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Woody Clark** ADDRESS AT WELL LOCATION **881 W. Lupin Street**
 MAILING ADDRESS **881 W. Lupin Street** **881 W. Lupin Street**
Pahrump, NV 89048

2. LOCATION **SW 1/4 NW 1/4 Sec. 28 T 20S** N/S **R 53E** E **Nye** County
 PERMIT NO. **39 061 35** Parcel No. **Cal Vada** Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	2	2
Grey Calache		2	16	14
Grey Clay		16	26	10
Grey Calache		26	31	5
Light Brown Clay		31	44	13
Brown Clay		44	58	14
Light Brown Clay	x	58	72	14
Brown Clay	x	72	99	27
Clay	x	99	125	26
Grey Clay	x	125	140	15

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)
 From **12 3/4** Inches To **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **Saw Cut**
 Size perforation **.188**

From **110** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **130** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL
 Static water level **55** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **Cool** °F Quality **Good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Strickland Construction Co., Inc.**
 Contractor
 Address **2301 Winery Road Suite 2**
 Contractor
Pahrump, NV 89041

Nevada contractor's license number issued by the State Contractor's Board **40277**



Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *Danny Strickland*
 By driller performing actual drilling on-site or contractor
 Date **8.14.97**

Date started **8/13/97** 19
 Date completed **8/13/97** 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	50	n/a	.50



KC