


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 691654
 Permit No. 162
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15555

1. OWNER Rod Hubbs ADDRESS AT WELL LOCATION 3620 W. Mesquite
 MAILING ADDRESS 3620 W. Mesquite
Pahrump, NV 89048

2. LOCATION SE 1/4 SW 1/4 Sec. 19S T 19S N/S R 52E E Nye County
 PERMIT NO. 27 171 15 N/A
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	2	2
Grey Calache		2	10	8
Brown Calache		10	24	14
Brown Clay		24	40	16
Light Brown Calache		40	55	15
Cream Clay	x	55	68	13
White Clay	x	68	79	11
Cream color Calache	x	79	93	14
Clay	x	93	110	17
Grey Clay	x	110	125	15
White Clay	x	125	140	15

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 137 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 3/4 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	141

Perforations:
 Type perforation Saw Cut
 Size perforation .188
 From 100 feet to 137 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road Suite 2 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed Larry Strickland
 By driller performing actual drilling on-site or contractor
 Date 8.15.97




Date started 8/14/97, 19____
 Date completed 8/14/97, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	n/a	.50



KC