WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69656
Permit No.
Basin 162

NOTICE OF INTENT NO. 15564

1. OWNER William Barrie
MAILING ADDRESS 3431 E. Mc Graw
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 3431 E. Mc Graw

2. LOCATION SE 1/4 NW 1/4 Sec. 18 T 21S N/S R 54E E Nye County
PERMIT NO. ____ Issued by Water Resources
45 264 03 Parcel No.
Green Saddle Ranch Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Silt		0	12	12
Brown Calache		12	18	6
White Clay		18	35	17
Brown Clay mixed with Gravel		35	47	12
Brown Clay		47	59	12
Brown Calache		59	70	11
Gravel	x	70	82	12
Brown Calache with Gravel	x	82	94	12
Gravel	x	94	110	16
Brown Calache	x	110	123	13
White Calache and Clay	x	123	134	11
Gravel	x	134	140	6

DCNR Received JAN 6 1998 LAS VEGAS OFFICE

Date started 10/2/97 , 19__
Date completed 10/2/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	n/a	.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 3/4	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation Saw Cut
Size perforation .188
From 120 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road Suite 2 Contractor
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland
By driller performing actual drilling on-site or contractor
Date 10-3-97

KC