WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69657
Permit No.
Basin 102

NOTICE OF INTENT NO. 15571

OWNER Alven Stewart
MAILING ADDRESS 1110 W. Mesquite
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 1110 W. Mesquite

2. LOCATION SW 1/4 SW 1/4 Sec. 32 T 19 N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 29-802-22 (Parcel No.) Rancho Del Sol (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	8	8
Brown Calache		8	12	4
Brown Clay		12	28	16
Brown Clay		28	38	10
Light Grey Clay		38	56	18
Brown Clay		56	65	9
Brown Calache	X	65	89	24
Light Brown Clay	X	89	102	13
Brown Calache	X	102	105	3
Brown Calache/Gravel	X	105	115	10
Brown Calache	X	115	129	14
Brown Clay	X	129	140	11

DCNR/D Received JAN 6 1998 LAS VEGAS

Date started 12/16/97, 19__
Date completed 12/16/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	0.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 7/8 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation Saw Cut
Size perforation .188
From 110 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the ~~on-site~~ driller 2086

Signed Larry Strickland
By driller performing actual drilling on-site of contractor

Date 12-31-97

KC