


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 69663
 Permit No. 102
 Basin 102



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15552

1. OWNER Levi Kiefer ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3951 Windsong Lane 3951 Windson Lane
Pahrump, NV 89041

2. LOCATION NW 1/4 NW 1/4 Sec. 13 T 20S N/S R 53E E Nye County
 PERMIT NO. 28 702 31 Charleston Park Ranchos
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	3	3
Grey Calach		3	10	7
Brown Clay		10	35	25
Grey Calache		35	44	9
Lt. Brown Clay	x	44	58	14
Brown Clay	x	58	70	12
Light Grey Calache	x	70	88	18
Grey Calache	x	88	101	13
Brown Clay	x	101	125	24
Clay	x	125	133	8
Grey Calache	x	133	140	7

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 138 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 3/4 inches 0 Feet 140 Feet
 _____ inches _____ Feet _____ Feet
 _____ inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation Saw Cut
 Size perforation .188
 From 110 feet to 138 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 44 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

Date started 8/13/97 19____
 Date completed 8/13/97 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>n/a</u>	<u>.50</u>


10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road Suite 2 Contractor
Pahrump, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Parry Strickland
 By driller performing actual drilling on-site or contractor
 Date 8.15.97



KC