


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 69667
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17322

OWNER Douglas Hudson ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4540 E. Laute Pahrump, NV 89048 4540 E. Laute
 2. LOCATION SW 1/4 NE 1/4 Sec. 29 T 21S N/S R 54E E Nye County _____
 PERMIT NO. 45-401-06 Fox Hollow
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Brown Loam		0	2	2
Brown Calache/Gravel		2	8	6
Grey Calache/Gravel		8	16	8
Brown clay/Gravel		16	18	2
Brown Calache/Gravel		18	35	17
Brown Calache /Gravel		35	50	15
Brown Clay/Gravel		50	69	19
Brown Calache/Gravel		69	80	11
Brown Clay/gravel		80	84	4
Light Brown Calache/Gravel		84	90	6
Brown Clay/Gravel		90	100	10
Brown Calache/Gravel		100	110	10
Brown Clay/Gravel	x	110	128	18
Brown Clay/Gravel	x	128	142	14
Brown Clay/Gravel	x	142	155	13
Brown Clay/Gravel	x	155	165	10
Brown Calache/Gravel	x	165	180	15

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 7/8 Inches 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	0.280	0	180

 Perforations:
 Type perforation SAW CUT
 Size perforation .188
 From 130 feet to 180 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 90 feet to 180 feet

Date started 12/31/97, 19____
 Date completed 12/31/97, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>.5</u>	<u>na</u>	<u>.50</u>

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc.
 Contractor
 Address 2301 Winery Road, Suite 2
 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed Larry Strickland
 By driller performing actual drilling on-site of contractor
 Date 1-5-98



KC