

OFFICE USE ONLY
 Log No. 29469
 Permit No. 1015
 Basin I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 531.170 and NAC 534.340

NOTICE OF INTENT NO. 32594

1. OWNER Jim Paschall ADDRESS AT WELL LOCATION same
 MAILING ADDRESS 7460 Baldwin Sparks, Nevada 89436
 2. LOCATION SE 1/4 NW 1/4 Sec. 12 T. 20N N/S R. 20E E Washoe County
 PERMIT NO. 083-050-16 Spanish Springs Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-------------------|--------------|------|-----|-----------|
| Static 10 ft. | | | | |
| Sand (GPM app 10) | | 52 | 65 | |
| Well Deepening | | | | |
| Brown clay, sandy | | 65 | 80 | 15 |
| Coarse sands | X | 80 | 86 | 6 |
| Brown clay | | 86 | 87 | 1 |
| Coarse Sands | X | 87 | 90 | 3 |
| Brown clay | | 90 | 91 | 1 |
| Coarse sands | | 91 | 95 | 4 |
| Brown clay | | 95 | 99 | 4 |
| Sand | | 99 | 102 | 3 |

8. WELL CONSTRUCTION
 Depth Drilled 102 Feet Depth Cased 102 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 1/8 Inches 52 Feet 102 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 5" | | .188 | 0 | 102 |

Perforations:
 Type perforation Factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 57 feet to 97 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal deepening
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 102 feet

9. WATER LEVEL
 Static water level 10 feet below land surface
 Artesian flow _____ G.P.M. 30+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date March 5, 1996

Date started 2-29-96 19_____
 Date completed 2-29-96 19_____

7. WELL TEST DATA

| TEST METHOD: | TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | | |
|--------------|---|-------------------------------|--------------|
| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
| Airlift | 30 + | | |
| | | | |
| | | | |