

OFFICE USE ONLY
Log No. 109673
Permit No. _____
Basin. 101
~~1008733~~
26355

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 933 Water Well

1. OWNER W. J. Rogers Shoes ADDRESS AT WELL LOCATION _____
MAILING ADDRESS _____

2. LOCATION Sec 22 T 20 N/S R 27 E Churchill County
PERMIT NO. 009-411-34
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand	L	0	27	27
Black Sand	L	27	30	3
Gray Silty Clay		30	47	17
Gray Silt	L	47	51	4
Brown Silt	L	51	67	16

8. WELL CONSTRUCTION
Depth Drilled 67 Feet Depth Cased 67 Feet
HOLE DIAMETER (BIT SIZE)
From To
10 Inches 0 Feet 50 Feet
10 Inches 50 Feet 67 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>129</u>	<u>.185</u>	<u>0</u>	<u>67</u>

Perforations:
Type perforation Machine Slot
Size perforation 6.75
From _____ feet to _____ feet
From 60 feet to 65 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 6-1/2 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started June 26, 1994
Date completed June 26, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>30</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Walsco Contractor
Address Box 888 Contractor
FALLON
Nevada contractor's license number issued by the State Contractor's Board 11952
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 112
Signed Walsco
By driller performing actual drilling on site or contractor
Date June 29, 1994