


OFFICE USE ONLY
 Log No. 691676
 Permit No. 101
 Basin.....


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36263

1. OWNER Lewis C. Currietta ADDRESS AT WELL LOCATION 4707 SOLAIS RD
 MAILING ADDRESS Fallen NV

2. LOCATION SW 1/4 SW 1/4 Sec. 16 T 18 N R 27 E Churchill County
 PERMIT NO. 6-435-61 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	2	2
Fine Black Sand		2	13	11
Fine to Med Sand	✓	13	23	10
Dark Clay		23	28	5
Fine to Med Sand	✓	28	37	9
Dark Clay		37	68	31
Fine to Med Sand	✓	68	87	19
Clay		87	90	3

8. WELL CONSTRUCTION
 Depth Drilled 90 Feet Depth Cased 90 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 90 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13</u>	<u>1 8/8</u>	<u>+ 2</u>	<u>90</u>

Perforations:
 Type perforation FACTORY MILLED
 Size perforation 10 x 4 1/2 Rows
 From 80 feet to 90 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 90 feet

Date started 11-6- 1997
 Date completed 11-11- 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>420</u>		<u>1 1/2</u>	

9. WATER LEVEL
 Static water level 9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eddco Exploration Inc Contractor
 Address 7780 CURRIK RD Contractor
Fallen, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11-12-97

RECEIVED
 97 NOV 14 AM 11:06
 STATE ENGINEERS OFFICE