

OFFICE USE ONLY
 Log No. 69679
 Permit No. 88
 Basin 1
 NOTICE OF INTENT NO. 37094

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER ERIN JONES ADDRESS AT WELL LOCATION 8175 So. Virginia Street #850-301 135 Del Mesa
 MAILING ADDRESS Reno, Nevada 89511 Reno, Nevada 89511
 2. LOCATION SE 1/4 NW 1/4 Sec 9 T 17N N/S R 19 E Washoe County
 PERMIT NO. 017-350-21 Steamboat Area
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay with gravels & boulder		0	27	27
Soft brown sandy clays		27	32	5
Brown clay with gravels		32	39	7
Black volcanic boulder		39	41	2
Brown clay with gravels		41	88	47
Brown sandy clays		88	141	53
Soft zone (app 1 GPM)	X	141	146	5
Dark brown sandy clay		146	170	24
Light brown sandy clay		170	191	21
Gray clay		191	213	22
Soft zone (app 3 GPM)	X	213	214	1
Gray green volcanic rock, broken		214	241	27
Black volcanic rock	X	241	291	50
Gray clay		291	341	50
Gray & green clay		341	367	26

8. WELL CONSTRUCTION
 Depth Drilled 367 Feet Depth Cased 367 Feet
 HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	254 Feet
6 1/3 Inches	254 Feet	367 Feet

 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	255
5"		.188	227	367

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 212 feet to 252 feet 6"
 From 227 feet to 247 feet 5"
 From 267 feet to 307 feet
 From 327 feet to 367 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50 feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 367 feet

Date started 12-16-97, 19____
 Date completed 12-19-97, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>4.7-5</u>			

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. 4.7-5 P.S.I.
 Water temperature warm °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling, Inc. By driller performing actual drilling on site or contractor
 Date January 5, 1998