

OFFICE USE ONLY
 Log No. 09681
 Permit No. _____
 Basin 176

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 33258

1. OWNER Mike & Dennis Keife ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3510 Chinee #100 Lot #4 Block #C Unit #1
Reno NV 89511

2. LOCATION NE 1/4 SW 1/4 Sec 9 T 28 Q/S R 58 east Elko County
 PERMIT NO. 007-03A-013 Ruby Valley Estates
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G.		0	15	15
Brown Clay With Multi colored grav		15	20	5
Multi colored grav	X	20	55	35
Multi colored grav with brown clay	X	55	120	65
T.D 120'				

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 5/8 Inches _____ Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1 1/2	120

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 120 feet to 50 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started May 20 1997
 Date completed May 20 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2Hrs.

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address 1800 1/2 Frazer Ave. Contractor
Sparks NV 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date May 19, 1997