

OFFICE USE ONLY
 Log No. 29683
 Permit No. 49595
 Basin 777 1877
 NOTICE OF INTENT NO. 3678

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Wendover Pipeline Authority ADDRESS AT WELL LOCATION Silver Zone Pass
 MAILING ADDRESS 801 Alpine Street
West Wendover, NV 89883
 2. LOCATION NE 1/4 NE 1/4 Sec. 18 T. 35 25 N. 68 E. Elko County
 PERMIT NO. 49595 Issued by Water Resources none available Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil sand & boulders		0	3	3
soft caliche		3	6	3
Sandy tan clay		6	40	34
Slightly cemented sand & gravels		40	416	376
Tan sandy clay		416	428	12
Sandstone (medium)		428	436	8
Tan sandy clay w/sand stringers		436	472	36
Moderate cemented sand & gravels		472	502	30
Dark grayish volcanic tuff		502	551	49
Moderate cemented sand & gravel w/light traces of red clay		551	820	269

8. WELL CONSTRUCTION
 Depth Drilled 820 Feet Depth Cascd 810 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 101 Feet
32 Inches
 From 101 Feet To 820 Feet
24 Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
26	141.93	.375	+1	101
16	52.36	.3125	+2	400
16	52.36	.3125	490	550
16	52.36	.3125	790	810

Perforations:
 Type perforation Johnson Hi-Cap Screen
 Size perforation .060
 From 400 feet to 490 feet
 From 550 feet to 790 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 101
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 810 feet

9. WATER LEVEL
 Static water level 261 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started August 8, 1997
 Date completed October 31, 1997

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>continuous</u>	<u>700</u>	<u>130</u>	<u>24</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thompson Drilling Co., Inc. Contractor
 Address 7277 Hawk Street Contractor
Las Vegas, NV 89118
 Nevada contractor's license number 4286A issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1851
 Signed Richard Thompson
 By driller performing actual drilling on site or contractor
 Date December 22, 1997