



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31428

1. OWNER James Pittman ADDRESS AT WELL LOCATION 5737 Old Hwy. 395N.
 MAILING ADDRESS 5737 Old Hwy. 395N. Carson City, NV 89704
 2. LOCATION NW 1/4 NW 1/4 Sec. 23 T. 16 N/S R. 19 E. Washoe County
 PERMIT NO. 62591 055-168-09 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	1	
Light brown DG		1	7	
Orange clay		7	16	
Gray sandy clay		16	69	
White D G	X	69	115	
Gray clay		115	121	
Multi colored				
Volcanic gravel	X	121	124	

8. WELL CONSTRUCTION
 Depth Drilled 124 Feet Depth Cased 124 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 124 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>-1</u>	<u>124</u>

Perforations:
 Type perforation mill slot
 Size perforation 1/8 x 3
 From 104 feet to 124 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 + Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 124 feet

9. WATER LEVEL
 Static water level: 24 feet below land surface
 Artesian flow: None G.P.M. None P.S.I.
 Water temperature: Cool °F Quality: Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name J & M Drilling Co. Contractor
 Address 1859 Hymer Ave. Contractor
Sparks, NV 89431
 Nevada-contractor's license number issued by the State Contractor's Board 41172
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
 Signed Bruce Miller
 By driller performing actual drilling on site or contractor
 Date 11-22-97

Date started 11-18, 1997
 Date completed 11-18, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>Approx. 20</u>	<u>120</u>	<u>3</u>

RECEIVED
 97 NOV 25 AM 10:15
 STATE ENGINEERS OFFICE