WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69690
Permit No.
Basin 179

NOTICE OF INTENT NO. 33062

1. OWNER Gary Sprouse
MAILING ADDRESS P.O. Box 150432
East Ely, NV 89315
ADDRESS AT WELL LOCATION 3 miles South of Ely

2. LOCATION NE ¼ SW ¼ Sec. 35 T. 16 N/S R. 63 E. White Pine County
PERMIT NO. Well No. 10 (Issued by Water Resources) APN 1062173 (Parcel No.) Blue Diamond Country Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	5	5
Gravel & Sand		5	200	195
Gravel Clay & Sand		200	220	20
Clay & Gravel		220	250	30
Clay		250	265	15
Clay/Sand & Gravel	x	265		
Water Seams			285	20
Clay Sand & Gravel		285	315	30
Clay & Gravel		315	340	25
Clay/Sand & Gravel		340		
Water Seams	x		375	35
Clay & Gravel		375	400	25

RECEIVED 97 NOV 19 AM 10:10 STATE ENGINEER'S OFFICE

Date started October 31, 19 97
Date completed November 4, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	122	2

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	400 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	400

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 6 rows
From 300 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 268 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date November 14, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627