

OFFICE USE ONLY  
 Log No. 6969  
 Permit No. \_\_\_\_\_  
 Basin 179

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33061

1. OWNER Jake Brunson ADDRESS AT WELL LOCATION Approximately 8 miles North of Ely  
 MAILING ADDRESS P.O. Box 1383  
McGill, NV 89318  
 2. LOCATION SE 1/4, NW 1/4 Sec. 14 T. 17 N. R. 63 E. White Pine County  
 PERMIT NO. 10 APN 0558105 Cross Timbers Subdivision Name  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Gravel & Sand		5	10	5
Gravel & Clay		10	15	5
Gravel & Sand		15	70	55
Water Bearing Sand & Gravel	x	70		
Gravel & Clay		95	105	10
Water Bearing Sand & Gravel	x	105		
Clay & Gravel		120	140	20

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	140

Perforations:  
 Type perforation Factory  
 Size perforation 1/8" x 2 1/2" 6 rows  
 From 60 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50 ft  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 59 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started October 27, 19 97  
 Date completed October 29, 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>200</u>	<u>61</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue  
Ely, NV 89301 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 14790  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641  
 Signed Juvel D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date NOVEMBER 14, 1997

RECEIVED  
 97 NOV 19 AM 10:10  
 STATE ENGINEERS OFFICE