

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 69695
 Permit No. 1378
 Basin 1378

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16401

1. OWNER BRUCE LARSON ADDRESS AT WELL LOCATION 1 1/2 MILES WEST OF HWY 376 TO LARSON OLHD. ROUND MTN NV.
 MAILING ADDRESS PO BOX 1920 ROUND MTN NEVADA 89045
 2. LOCATION NW 1/4 SW 1/4 Sec 4 T 10 N/S R 43 E NYE County
 PERMIT NO. 12-461-67 LARSON Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN CLY		0	9	9
BIG GRAVEL		9	13	4
BRN CLY		13	17	4
SMALL GRAVEL		17	20	3
TAN CLY		20	41	21
SAND		41	43	2
WHITE CLY		43	49	6
SMALL GRAVEL		49	51	2
TAN CLY		51	64	13
COARSE SAND		64	67	3
BRN CLY		67	74	7
MED GRAVEL		74	77	3
TAN CLY		77	81	4
COARSE SAND		81	83	2
BRN CLY		83	86	3
SMALL GRAVEL & SAND		86	94	8
WHITE CLY		94	109	14
SMALL GRAVEL	X	109	113	5
TAN CLY		113	148	35
SMALL GRAVEL	X	148	154	6
BOLDERS & BIG GRAVEL	X	154	163	9
TAN CLY		163	165	2

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 165 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 165 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>71</u>	<u>165</u>

Perforations:
 Type perforation MILLED
 Size perforation 3 X 1/8 24 SLATS P.I.F.
 From 145 feet to 165 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
X ENVIRO P146
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I.
 Water temperature COLO °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WOYTEK DRILL CO INC Contractor
 Address 2220 STOWE DR. RENO NEVADA 99511 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 024521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Thomas on Harris
 By driller performing actual drilling on site or contractor
 Date 12-8-97

Date started 12-5 19 97
 Date completed 12-6 19 97

7. WELL TEST DATA

TEST METHOD:		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>		<u>3 HRS</u>