

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16403

1. OWNER BRUCE LARSON ADDRESS AT WELL LOCATION 1 1/2 MILES WEST OF HWY 376 TO LARSON BLVD
 MAILING ADDRESS PO Box 1920 ROUND MTN NEVADA
ROUND MTN NEVADA 89045
 2. LOCATION NW 1/4 SW 1/4 Sec 4 T 10 N/S R 43 F NYE County
 PERMIT NO. 12-461-69 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN CLY		0	9	9
GRAVEL		9	14	5
BRN CLY		14	37	19
COARSE SAND		37	33	2
GRAVEL		33	38	5
TAN CLY		38	44	6
GRAVEL		44	51	7
TAN CLY		51	72	21
GRAVEL & SAND		72	89	17
WHITE CLY		89	93	4
FINE SAND		93	95	2
BRN CLY		95	113	18
SMALL GRAVEL		113	119	6
TAN CLY		119	138	19
GRAVEL	Y	138	144	6
BRN CLY		144	146	2
BIB GRAVEL	X	146	165	19

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 165 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 165 Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>71</u>	<u>165</u>

Perforations:
 Type perforation MILLED
 Size perforation 3 1/8
 From 145 feet to 165 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Y ENVIRO P146
 Gravel Packed: Yes No
 From feet to feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow NO G.P.M. P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WOYTEK DRILL CO INC. Contractor
 Address 7220 STONE DR Contractor
RENO NEVADA 89511
 Nevada contractor's license number issued by the State Contractor's Board 024521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1442
 Signed Thomas Om Harris
 By driller performing actual drilling on site or contractor
 Date 12-15-97

Date started 12-12 1997
 Date completed 12-15 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u> </u>	<u>4 hrs</u>