

OFFICE USE ONLY  
Log No. 109698  
Permit No. 1378  
Basin 1378

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16402

1. OWNER BRUCE LARSON ADDRESS AT WELL LOCATION 1 1/2 MILES WEST OF HWY 376 TO LARSON BLVD ROUND MTN NEVADA  
MAILING ADDRESS PO BOX 1920 ROUND MTN NEVADA 89045  
2. LOCATION NW 1/4 SW 1/4 Sec. 4 T 10 N/S R. 43 E NYE County  
PERMIT NO. 12-461-68 Issued by Water Resources Parcel No. 12-461-68 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BKN CLY		0	9	9
GRAVEL		9	14	5
BKN CLY		14	32	18
COARSE SAND		32	34	2
BKN CLY		34	46	12
SAND		46	47	1
WHITE CLY		47	58	11
SMALL GRAVEL		58	60	2
TAN CLY		60	72	12
GRAVEL & SAND		72	78	6
BKN CLY		78	80	2
MED GRAVEL	X	80	88	8
BKN CLY		88	91	3
GRAVEL		91	95	4
BKN CLY		94	110	16
GRAVEL		110	114	4
TAN CLY		114	155	41
BLK GRAVEL	X	155	165	10

8. WELL CONSTRUCTION  
Depth Drilled 165 Feet Depth Cased 165 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
10 5/8 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 165 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>71</u>	<u>165</u>

Perforations:  
Type perforation 3X MILLED  
Size perforation 3X 1/8  
From 80 feet to 90 feet  
From 155 feet to 165 feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No X ENVIRO PLUS  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 12 feet below land surface  
Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name WOYTEK DRILL CO INC. Contractor  
Address 2220 STOWE DR RENO NEVADA 89511 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 024521A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442  
Signed Thomas M. Harris  
By driller performing actual drilling on site or contractor  
Date 12-11-97

Date started 12-9 1997  
Date completed 12-10 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>		<u>4 HRS</u>