

OFFICE USE ONLY  
Log No. 169699  
Permit No. 137B  
Basin

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14404

1. OWNER RAY JENSEN ADDRESS AT WELL LOCATION 1/2 MILES WEST OF HWY 376 ON EAST SIDE OF LARSON BLVD. ROUND Mtn., NV  
MAILING ADDRESS PO BOX 335 TONOPAH NEVADA 89049  
2. LOCATION NW 1/4 SW 1/4 Sec 4 T 10 N/S R. 43 E NYE County  
PERMIT NO. 012-461-26 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN CLY		0	9	9
GRAVEL		9	14	5
BRN CLY		14	19	5
SMALL GRAVEL		19	24	5
TAN CLY		24	34	10
COARSE SAND		34	36	2
TAN CLY		36	47	11
GRAVEL & SAND		47	54	7
BRN CLY		54	61	7
MED GRAVEL		61	65	4
BRN CLY		65	81	16
GRAVEL		81	84	3
WHITE CLY		84	87	3
SAND & SMALL GRAVEL		87	93	6
TAN CLY		93	101	8
COARSE SAND		101	103	2
BRN CLY		103	111	8
GRAVEL		111	114	3
TAN CLY		114	135	21
SMALL GRAVEL	X	135	138	3
WHITEISH CLY		138	148	10
GRAVEL & SOME CLY STRINGS	X	148	165	17

8. WELL CONSTRUCTION  
Depth Drilled 165 Feet Depth Cased 165 Feet  
HOLE DIAMETER (BIT SIZE)  
From 105/8 Inches 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 165 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>71</u>	<u>165</u>

Perforations:  
Type perforation MILLED  
Size perforation 3-1/8  
From 145 feet to 165 feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 ENVIRO ALUB  
Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 12 feet below land surface  
Artesian flow NO G.P.M. P.S.I.  
Water temperature COLD °F Quality GOOD

Date started 12-15, 19 97  
Date completed 12-16, 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>		<u>4 HRS</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name WOYTEK DRILL CO INC Contractor  
Address 2220 STOWE DR. Contractor  
RENO NEVADA 89511  
Nevada contractor's license number issued by the State Contractor's Board 024521A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442  
Signed Thomas om Harris  
By driller performing actual drilling on site or contractor  
Date 12-17-97