WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69707
Permit No.
Basin 85

NOTICE OF INTENT NO. 20097

1. OWNER Gail Yerman / Edward Johanns
MAILING ADDRESS 5025 So McCarran Blvd # 235
Reno, Nv 89502

ADDRESS AT WELL LOCATION 630 Valle Verde
Lot 35

2. LOCATION NE ¼ SW ¼ Sec. 20 T. 21 N/S R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-690-35 (Parcel No.) — Spanish Springs Ranches # 2 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	23	23
Brown clay with white rock		23	24	1
Brown clay		24	80	56
Hard brown clay		80	175	95
Gray silt		175	342	167
Red medium hard rock & silt		342	344	2
Red hard rock		344	365	21
Purple & gray volcanic rock		365	385	20
Purple clay		385	420	35
Red rock		420	430	10
Purple gray volcanic rock- broken clay		435	5.99	164
Seepage - little		496	499	3
[redacted]				

Date started 9/3/92, 19
Date completed 9/4/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 599 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
8 ½	Inches	50	Feet	599	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
NONE				

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [ ] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [ ] No
From feet to feet

9. WATER LEVEL
Static water level estimate half bore feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L (Contractor)
Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132
Signed Roger M Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627