

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 00515

1. OWNER Western Logic Resoures ADDRESS AT WELL LOCATION Bugs Fl Long valley RV  
 MAILING ADDRESS 2nd floor 1842 14th St NW Calgary Alberta  
 2. LOCATION N.E. 1/4 NW 1/4 Sec. 33 T. 22 N. R. 59 E. White Pine County  
 PERMIT NO. OG 207 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	2	2
Cobbles sand		2	18	16
Sand Sluie		19	48	30
Cemented Gravel		48	107	119
sand stone	X	107	182	15
Cemented Gravel		182	197	15
gravel sand	X	197	232	35
Cemented Gravel		232	241	9
gravel sand	X	241	247	6
Cemented Gravel		247	250	3

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 250 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>.188</u>	<u>0</u>	<u>250</u>

Perforations:  
 Type perforation Free slot  
 Size perforation 1/8 x 1/2  
 From 200 feet to 245 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 250 feet

9. WATER LEVEL  
 Static water level 162 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started Dec 20 1997  
 Date completed Dec 20 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u>0</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SHILO WELL SERVICE Contractor  
 Address P.O. Box 10 Contractor  
EIKO NV  
 Nevada contractor's license number issued by the State Contractor's Board 0038169  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438  
 Signed Shane Bennett  
 By driller performing actual drilling on site or contractor  
 Date Dec - 20 97