

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30574

1. OWNER Harold W Goodwin ADDRESS AT WELL LOCATION 6 miles North of Wells NV  
MAILING ADDRESS P.O. Box 94 Wells NV

2. LOCATION NW 1/4 NW 1/4 Sec 17 T 38 N R 63 E E1K0 County \_\_\_\_\_  
PERMIT NO. \_\_\_\_\_ Parcel # 4 Subdivision Name M03 and M  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Caliche		2	4	2
Clay Sand		4	16	12
gravel clay		16	27	11
Sandstone		27	63	36
gravel clay	X	63	92	29
Sandstone		92	133	41
gravel Sand	X	133	167	34
Sandstone		167	175	8

8. WELL CONSTRUCTION  
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 0 Feet 175 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>175</u>

Perforations:  
Type perforation Fee slot  
Size perforation 1/8 x 6  
From 150 feet to 170 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 175 feet

Date started Dec 3, 1997  
Date completed Dec 3, 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>207</u>	<u>22</u>	<u>2</u>

9. WATER LEVEL  
Static water level 93 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Steve Well Service Contractor  
Address P.O. Box 10 E1K0 NV Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0038169  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438  
Signed Shan Bennett  
By driller performing actual drilling on site or contractor  
Date Dec 5-97