

OFFICE USE ONLY
 Log No. 69723
 Permit No. 102
 Basin. 102
 NOTICE OF INTENT NO. 50151

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Keith Fenalton ADDRESS AT WELL LOCATION Winchester St. Silver Springs NV
 MAILING ADDRESS Silver Springs NV 89409

2. LOCATION S10 1/4 NE 1/4 Sec. 18 T. 17 N/S R. 25 E Lyon County
 PERMIT NO. 17-313-15 Parcel No. 5096 BRUSH NO. 3 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & SILT		0	30'	30'
Gray Clay		30	107'	77'
SAND & SILT	✓	107'	116'	9'
Gray Clay		116'	131'	15'
COURSE SAND	✓	131'	140'	9'

97 NV 30 PERM 26
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 11" Inches To 140 Feet
 From 0 Feet To 140 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>1.88</u>	<u>91</u>	<u>140'</u>

Perforations:
 Type perforation Air Perforator
 Size perforation 1/8 x 1" 4# Rows
 From 130' feet to 140' feet
 From 130' feet to 140' feet
 From 130' feet to 140' feet
 From 130' feet to 140' feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60'
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100' feet to 140' feet

9. WATER LEVEL
 Static water level 32' feet below land surface
 Artesian flow OK G.P.M. OK P.S.I. OK
 Water temperature 64 °F Quality Clear

Date started 11/20 19 97
 Date completed 11/25 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>30 Gpm. Air Test</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Inc. Contractor
 Address P.O. Box 599 Contractor
Silver Springs NV
 Nevada contractor's license number 0031841
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
 Signed William Leach
 By driller performing actual drilling on site or contractor
 Date Dec 23/97