WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69734
Permit No.
Basin 83

NOTICE OF INTENT NO. 35151

1. OWNER All Lite Aggregate
MAILING ADDRESS

ADDRESS AT WELL LOCATION Lockwood Canyon
1580 Twin Oaks Rd
Reno, Nev.

2. LOCATION NW ¼ NW ¼ Sec. 35 T. 19 N/S R 21 E Storey County
PERMIT NO. W489/63525-T
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	16	
Tan Clay		16	57	
Gray Clay		57	96	
Gray Shale with Cracks		96	128	
Hard Shale With cracks	✓	128	172	
Hard shale		172	208	
Hard Shale With Cracks	✓	208	241	
Hard Shale		241	263	
Hard Shale With Cracks	✓	263	283	
Gray clay		283	304	
Hard shale with cracks	✓	304	500	

Date started 11-5, 1997
Date completed 11-17-, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250 GPM		

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)
12 3/4 Inches From 0 Feet To 500 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		3/16	+1	500

Perforations:
Type perforation Mill slot
Size perforation 18x3 Double Row
From 100 feet to 120 feet
From 140 feet to 160 feet
From 180 feet to 200 feet
From 220 feet to 240 feet
From 260 feet to 280 feet
300 to 500 per ft

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 500 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc
Contractor
Address Po Box 599
Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1187
Signed [signature]
By driller performing actual drilling on site or contractor
Date 11-18-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627