

OFFICE USE ONLY
 Log No. 69754
 Permit No. 48
 Basin Spring Creek
 NOTICE OF INTENT NO. 35956

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Khoury Leasing Co
 MAILING ADDRESS 259 N Spring Creek Parkway Elko NV 89801
 ADDRESS AT WELL LOCATION Spring Creek Parkway
 2. LOCATION NW 1/4 SE 1/4 Sec. 33 T 34 N/S R. 56 E Elko County
 PERMIT NO. 006-310-012 Issued by Water Resources Parcel No. Spring Creek Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary PVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Loam</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>SOFT SANDSTONE</u>		<u>2</u>	<u>25</u>	<u>23</u>
<u>BROWN SANDSTONE</u>		<u>25</u>	<u>29</u>	<u>4</u>
<u>SOFT TAN SANDSTONE</u>		<u>29</u>	<u>69</u>	<u>40</u>
<u>CLAY</u>		<u>69</u>	<u>74</u>	<u>5</u>
<u>CLAY mix with Gravel</u>	<u>X</u>	<u>74</u>	<u>83</u>	<u>9</u>

8. WELL CONSTRUCTION
 Depth Drilled 87 Feet Depth Cased 83 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 10 Feet
 From 6 Inches To 8 3/4 Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>Sch 40</u>	<u>+1</u>	<u>82</u>

Perforations:
 Type perforation slots
 Size perforation # 12
 From 8.5 feet to 13.5 feet
 From 23.5 feet to 77 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 10
 Placement Method: Pumped Poured Benitonte seal 4'-6"
 Gravel Packed: Yes No
 From 6' feet to 83' feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fertig Drilling Co Contractor
 Address P.O. Box 525 Elko NV 89801 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Paul Fertig
 By driller performing actual drilling on site or contractor
 Date 10-14-97

Date started 10-23 1997
 Date completed 10-28 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Approx</u>	<u>4</u>		<u>3.5</u>

RECEIVED
 07 NOV 17 AM 11:25
 STATE ENGINEER'S OFFICE