WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69770
Permit No.
Basin 102

NOTICE OF INTENT NO. 36844

1. OWNER Peter Jones
MAILING ADDRESS 3232 Tulare Avenue
Richmond, CA 94804

ADDRESS AT WELL LOCATION
5155 Fourth ST, Silver Springs, NV

2. LOCATION NE 1/4 NE 1/4 Sec. 11 T 17N N/S R 25E E Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. 17-226-12 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	50	40
Gray Clay		50	95	45
Fine Brown sand		95	97	2
Gray Sand		97	107	10
Gray Clay		107	130	23
Brown Silt		130	150	20
Brown Clay		150	157	7
Fine Sand		157	170	13
Gray Clay		170	175	5
Fine Gray Sand		175	184	9
Brown Sand	X	184	197	13

RECEIVED 97 DEC 9 AM 11:16 STATE ENGINEER'S OFFICE

Date started 12/11/97, 19__
Date completed 12/12/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 197 Feet Depth Cased 197 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10	Inches	0 Feet	197 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	197

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 187 feet to 197 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 195 feet

9. WATER LEVEL
Static water level 43 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on-site or contractor

Date 12-17-97