WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69779
Permit No.
Basin 101

NOTICE OF INTENT NO. 36753

1. OWNER Kelly Hiatt
MAILING ADDRESS P.O. Box 1059
Fallon, NV 89407

ADDRESS AT WELL LOCATION
5435 Reno Hwy, Fallon, NV 89406

2. LOCATION SW 1/4 NE 1/4 Sec. 29 T 19N N/S R 28E E Churchill County
PERMIT NO. 54201 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial (Commercial) [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	12	12
Brown Clay		12	16	4
Brown Sand		16	18	2
Brown Clay		18	19	1
Coarse Brown Brown Sand		19	37	18
Sandy Clay		37	42	5
Sandy Green Clay		42	49	7
Black Clay		49	51	2
Green Sandy Clay		51	55	4
Green Gray Sand		55	75	20
Brown Clay		75	77	2
Coarse Brown Sand		77	87	10
Brown Clay		87	88	1
Gravel		88	95	7
Green Sandy Clay		95	97	2
Blue Green Clay		97	108	11
Gray Green Sand		108	110	2
Gray Clay		110	131	21
Green Sand		131	137	6
Gray Clay		137	139	2
Sand Green		139	140	1
Green Clay		140	143	3
Clay		143	155	12
Brown Sand & Clay		155	158	3
Brown Sand & Gravel	X	158	163	5
Brown Clay		163	171	8

Date started 8/5/97, 19__
Date completed 8/5/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 171 Feet Depth Cased 171 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	171	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE 6 5/8" OD SURFACE CSG TO 10 FT.
5" CSG 15 PVC THREADED

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	3.91	.258	0	171

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 159 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 171 feet

9. WATER LEVEL
Static water level 22.3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1696

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 9-5-97