WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69781
Permit No.
Basin 73A

NOTICE OF INTENT NO. 36418

1. OWNER TYCO
MAILING ADDRESS 22575 DORSIE LANE
LOVELOCK, NV 89419

ADDRESS AT WELL LOCATION
22575 DORSIE LANE Lovelock, NV

2. LOCATION SW 1/4 NE 1/4 Sec. 21 T 30 N/S R 33 E ~~CHURCHILL~~ Pershing County
PERMIT NO. _____ Issued by Water Resources
1042207 Parcel No.
Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	50	50
BROWN SAND		50	59	9
BROWN CLAY		59	91	32
MC GRAVELS/SANDS	X	91	145	54

Date started 9/28/97, 19__
Date completed 9/28/97, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.
20		1 hr.

8. **WELL CONSTRUCTION**
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	145	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	145

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 135 feet to 145 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured

Seal Type:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From ____ feet to ____ feet

9. **WATER LEVEL**
Static water level 10.11 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature COOL °F Quality UNTESTED

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp.
Contractor
Address 305 E. WILLIAMS AVE. P. O. BOX 888
Contractor
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 10-26-97