

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 69790
 Permit No. 101
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36404

1. OWNER LAHONTAN MANUFACTURED HOMES ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4700 RENO HWY 1390 RICE ROAD
FALLON, NV 89406

2. LOCATION SW 1/4 NE 1/4 Sec. 24 T 19 N/S R 28 E CHURCHILL County
 PERMIT NO. 008 326 31
 Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	13	13
BROWN CLAY		13	15	2
BROWN SAND		15	30	15
BROWN CLAY		30	32	2
BROWN SILT		32	40	8
GREY SAND		40	60	20
BLACK SILT		60	82	22
GREY CLAY		82	85	3
BROWN SAND		85	95	10
GREY SAND		95	150	55
BLACK SILT		150	170	20
GREY SAND		170	198	28
BROWN CLAY		198	205	7
BROWN SAND	X	205	232	27

8. WELL CONSTRUCTION
 Depth Drilled 232 Feet Depth Cased 232 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 3/4 Inches 0 Feet 50 Feet
6 1/8 Inches 50 Feet 232 Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	232

Perforations:
 Type perforation MACHINE SLOT
 Size perforation .080
 From 207 feet to 214 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement *Neat Cement*
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 35.6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Welsco Drilling Corp. Contractor
 Address 305 E. WILLIAMS AVE. P. O. BOX 888 Contractor
FALLON, NV 89407
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 10/26/97

Date started 10/13/97, 19____
 Date completed 10/13/97, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>		<u>1 hr.</u>