WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69793
Permit No.
Basin 101

NOTICE OF INTENT NO. 37380

1. OWNER GNS CONSTRUCTION
MAILING ADDRESS 4240 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION
5805 DILLON

2. LOCATION NE 1/4 NW 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County

PERMIT NO. (Issued by Water Resources) | 08-172-09 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	15	15
BROWN CLAY		15	19	4
BROWN SAND		19	30	11
GREY SAND		30	50	20
BLACK SILT		50	70	20
GREY SAND		70	80	10
GREY CLAY		80	85	5
BROWN SAND	X	85	98	13

Date started 10/27/97, 19__
Date completed 10/27/97, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

8. WELL CONSTRUCTION

Depth Drilled 98 Feet Depth Cased 98 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/8	Inches	50	Feet	98	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	98

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 91 feet to 96 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 13.6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address 305 E. WILLIAMS AVE. P. O. BOX 888 (Contractor)
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed (By driller performing actual drilling on-site or contractor)
Date Nov-4-97